










Office Building - MEP Discrepancies



Model Name	concept model_V9_EQstories_ARCH Version: 9.0
Checker	Administrator
Organization	
Date	February 17, 2014
concept model_V9_EQstories_ARCH	Date: 2014-02-07 12:42:34 Application: Autodesk Revit Architecture 2014 (ENU) IFC: IFC2X3
concept model_V13_MEP_Mech	Date: 2014-02-07 11:21:41 Application: Autodesk Revit MEP 2014 (ENU) IFC: IFC2X3

Presentation 4											
Number	Id	Location	Date	Author	Picture	Issue comment	Responsibilities	Action Required	Action Taken	Status	Components
1	47	(B) 3rd floor, (B) Level 1, (B) Level 0, (B) 2nd floor	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Intersections Between Ducts and cable tray				Open	(B) Cable Carrier.1.10 (B) Duct.3.23 (B) Cable Carrier.3.45 (B) Cable Carrier Fitting.0.25 (B) Cable Carrier.1.9 (B) Duct.2.194 (B) Cable Carrier.3.50
2	48	(B) Level 0 Corridor[048]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Intersections Between Ducts and sprinkler pipe				Open	(B) Duct.0.118
3	49	(A) Ground floor Office[003]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Intersections in sprinkler pipes				Open	(B) Pipe Fitting.0.30 (B) Pipe.0.377
4	59	(A) 3rd floor Corridor[321]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Duct (other than large ones) Intersections				Open	(B) Duct Fitting.3.186 (B) Duct.3.206
5	60	(A) 1st floor Office[143]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Duct (other than large ones) Intersections				Open	(B) Duct Fitting.1.298 (B) Duct.1.293
6	61	(A) 4th floor Open office[411]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Duct Intersections				Open	(B) Duct.3.33 (B) Duct Fitting.3.14
7	62	(B) Level 0 Office[003]	17-Feb-2014	Administrator		Administrator, Feb 17, 2014: Intersections in HVAC Models				Open	(B) Pipe Fitting.0.241 (B) Pipe Fitting.0.245 (B) Pipe Fitting.0.330 (B) Pipe Fitting.0.409